



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/WZ/School/2025/WZ/283

Dated:- 26/03/2025

FIRE SAFETY CERTIFICATE

Certified that the SGN Public School, Located at H-243, Kunwar Singh Nagar, Nangloi, New Delhi-110041, comprised of Ground + 01 Upper Floor only, owned/occupied by Sadguru Consciousness Society (Regd.), was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2021/1065 dated 23/12/2021. The said premise was re-inspected by the officer concerned of this department on 10/03/2025 in the presence of Sh. Kunal Swami (Director) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 26/03/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 26/03/2025 at New Delhi by

(Atul Gang)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, SGN Public School, H-243, Kunwar Singh Nagar, Nangloi, New Delhi-110041,

Conditions for the validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

Chitrananda
Principal
S.G.N. Public School
H-243, Kunwar Singh Nagar,
Nangloi, Delhi-110041

SK
Manager
S.G.N. Public School
H-243, Kunwar Singh Nagar,
Nangloi, Delhi-110041