



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No. DHOWZ/2026/D - 2503

Dated: 20/01/26

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter no D-384/HD/WZ/170 dated 19 07 2019 The school premises were re- inspected by officials of the Public Health Department in the presence of school management and found to be in sanitary and hygienic condition from a health point of view. The details are as follow

Name of the school: M/s S.G.N PUBLIC SCHOOL

Address of School: H-243, KUNWAR SINGH NAGAR, OPP NILOTHI MORE
NAJAFGARH ROAD NANGLOI NEW DELHI-110043

Shifts ONE Timing: MORNING

No. of Students Boys: 422 Girls: 318 Total: - 740

No. of Staff (Teachers): Female: 21 Male: 07 Total: 28

That the accommodation provided for the class rooms as calculated.

- | | |
|---|-----------|
| 1. (A) On floor space is sufficient | Yes |
| (B) On Cubic space is sufficient | Yes |
| 2. That the classrooms are well ventilated | Yes |
| 3. That the classrooms are kept neat and clean | Yes |
| 4. That the classrooms are well lighted | Yes |
| 5. That the drinking water is wholesome | Wholesome |
| 6. That the latrines arrangement is adequate and there are sufficient latrines. | |
| 7. That urinals arrangement is adequate and there are sufficient urinals | |

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue

~~Dy. Health Officer~~
~~West Zone~~
Dy. Health Officer
West Zone

Chitrangda

Principal
S.G.N. Public School
H-243, Kunwar Singh Nagar,
Nangloi, Delhi-110041

MC
Manager
S.G.N. Public School
H-243, Kunwar Singh Nagar,
Nangloi, Delhi-110041



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



International Year
of Cooperatives

Water Sample Analysis report of samples collected from "S.G.N. Public School" H-243, Kunwar Singh Nagar, Opp. Nilothi More, Najafgarh road, Nangloi, New Delhi – 110041 Vide challan no:-265 dated:-29.12.2025.
S1:- Borewell water at above site. S2:- Drinking point (RO) at above site.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY						
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	30.12.2025	
2.	Date of Analysis	-----	--	--	01.01.2026	
3.	Colour	CU	5.0	15	Clear	
4.	Odour	-----	No. Objectionable		No Obj.	
5.	Turbidity	N.T.U.	1.0	5.0	4.0	1.2
6.	PH value	-----	6.5	8.5	7.58	7.88
7.	Electrical Conductivity	µmho/cm	--	--	3917	377.5
8.	Total dissolved solids	mg/l	500	2000	2546	245.4
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	300	108
11.	Total Hardness	mg/l	200	600	655	158
12.	Calcium Hardness	mg/l	--	--	246	106
13.	Magnesium Hardness	mg/l	--	--	409	46
14.	Calcium as Ca	mg/l	75	200	98.4	42.4
15.	Magnesium as Mg	mg/l	30	100	98.16	11.04
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	1.0	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	52.4	2.6
19.	Sulphate	mg/l	200	400	310	36
20.	Chloride	mg/l	250	1000	906	24
21.	Fluoride	mg/l	1	1.50	1.46	0.28
22.	Dissolve Iron	mg/l	1	N.R.	0.36	0.06
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	NIL	NIL
BACTERIOLOGICAL EXAMINATION						
25.	T. Coli-form per 100 ml at 37°C	MPN	0		64	0

REMARKS:- As per tested parameters Sample - S1 can not be used for drinking purpose whereas Sample- S2 can be used for drinking purpose.

[Signature]
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

[Signature]
CHEMIST

[Signature]
Chitrangda

Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

S.G.N. Public School
H-243, Kunwar Singh Nagar,
Nangloi, Delhi-110041

[Signature]
A/BACT.

[Signature]
Manager
S.G.N. Public School
H-243, Kunwar Singh Nagar,
Nangloi, Delhi-110041